



JUGOINSPEKT BEOGRAD AD

Direkcija CA – SERTIFIKACIONO TELO

JUGOINSPEKT BEOGRAD AD, Direkcija CA, Čika Ljubina 8/V,
tel. 011 3032-145, fax. 011 2626-349
web:www.jugoinspekt.com E-mail – dirca@sezampro.rs.

H001

POTVRDA O USAGLAŠENOSTI

CONFIRMATION OF CONFORMITY

Broj: P1-1281/13
No.

Opis proizvoda: <i>Product description:</i>	KLIMA UREĐAJ
Tipaska oznaka, model: <i>Type designation, model:</i>	ARNU07GQAA2, ARNU09GQAA2, ARNU12GQAA2, ARNU15GQAA2.
Podnosilac zahteva: <i>Applicant:</i>	PREDSTAVNIŠTVO LG ELECTRONICS MAGYAR KFT., Španskih boraca 3/B, Beograd.
Proizvođač: <i>Manufacturer:</i>	LG Electronics – Južna Korea
Vrednovana dokumentacija proizvođača <i>Evaluated Documentation of producer</i>	
Ispitni izveštaj, broj: <i>Test report, number:</i>	13603326 001
Izdat od: <i>Issued by:</i>	TÜV Rheinland LGA Products, Nemačka.
Deklaracija o usaglašenosti: <i>Declaration of conformity:</i>	LG Electronic Inc., Holandija.
Standard: <i>Standards:</i>	SRPS EN 55014-1:2010/A1:2010; SRPS EN 55014-2:2009; SRPS EN 61000-3-2:2008/A2:2011; SRPS EN 61000-3-3:2009;
<p>Na osnovu gore navedene dokumentacije utvrđeno je da gore navedeni proizvod zadovoljava zahteve Pravilnika elektromagnetskoj komaptibilnosti-EMC(Sl. glasnik RS, 13/2010).</p> <p>On the basis of the above mentioned documentation is found that above mentioned product fulfils the requirements of the Regulation of electromagnetic compatibility-EMC(Sl. glasnik RS, 13/2010)</p> <p>Nastale promene u specifikaciji , tipu/modelu, komponentama, električnim karakteristikama proizvoda koji utiču na usaglašenost sa navedenim Pravilnikom moraju se prijaviti "Jugoinspekt"-u a.d. Beograd.</p> <p>Any changes occur in the specification type/model, components or the design, electrical construction which may influence on EMC of the product shall be forward to certification body.</p>	

Mesto i datum izdavanja:
Place and date:

Beograd, 02.07.2013.

Važi do:
Valid Until:

02.07.2016

Pečat i Potpis ovlašćenog lica:
Seal and Sign:

