

COPPER COM D.O.O.
PARTIZANSKA BB
31205 SEVOJNO

INSPECTION CERTIFICATE

Type 3.1 acc. EN 10204

Certificate No : 1000321540

DATE: 02.08.2017

Delivery No : 0085150719

Customer	COPPER COM D.O.O.		
Cust's Ref No	12/82905	Cust's Part No	
Our Order No	1200082907 / 300	Quantity	501,30 KG
		Inspection Lot	020000435877

Designation	COPPER TUBES 012,700x0,80x50000 PNC FOR REFRIGERATION USE,		
according to	EN 12735-1, R220		
Material	Cu-DHP		
Chem. Anal.:	CU>99,90-P:0,015-0,040	OK	

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODav	mm	12,660 - 12,740	12,705	1
Smin	mm	>=0,720	0,730	1
Smax	mm	<=0,880	0,780	1
LENGTH	mm	>=50000	50120	1
Rm	N/mm ²	>=220,0	244,0	1
A50	%	>=40,0	53,0	1
EXPANSION	%	>=30,0	OK	1
C TOT. RES. IN.	mg/dm ²	<=0,38	0,08	1
ECT EN 1971	%	100	OK	-

DECLARATION OF COMFORMITY

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance system applied to monitor their production, complies to the requirements of ISO 9001/2008, independently certified by TÜV HELLAS, with registration No 041070119.

Athens

03.08.2017

Q.C. INSPECTOR

Q.A. MANAGER



D. SKARMOUTSOS

ISSUE C

REV 1

DATE JUL-2014

FORM N3

e-mail: info@halcor.com
website: www.halcor.com
VAT number: EL094061318

Offices & Copper Tube Plant (Mailing Address)
62nd km Athens-Lamia National Road,
GR-32011 Inofita-Viotia, GREECE
Tel.: +30 22620 48111, Fax: +30 22620 48911

Foundry
60th km Athens-Lamia National Road,
GR-32011 Inofita-Viotia, GREECE
Tel.: +30 22620 53479, Fax: +30 22620 53925

Domestic Sales Dept
252 Pireos str.
GR-17778, Tavros, Athens, GREECE
Tel.: +30 210 4898111, Fax: +30 210 4898397