

COPPER COM D.O.O.  
PARTIZANSKA BB  
31205 SEVOJNO

## INSPECTION CERTIFICATE

Type 3.1 acc. EN 10204

Certificate No : 1000323476

DATE: 24.08.2017

Delivery No : 0085151481

Customer	COPPER COM D.O.O.		
Cust's Ref No	12/82905	Cust's Part No	
Our Order No	1200082907 / 310	Quantity	492,80 KG
		Inspection Lot	020000436160

Designation **COPPER TUBES 015,875x0,90x50000 PNC FOR REFRIGERATION USE,**

according to **EN 12735-1, R220.**

Material **Cu-DHP**  
Chem. Anal.: **CU>99,90-P:0,015-0,040** OK

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODav	mm	15,835 - 15,915	15,875	1
Smin	mm	>=0,810	0,810	1
Smax	mm	<=0,990	0,880	1
LENGTH	mm	>=50000	50150	1
Rm	N/mm <sup>2</sup>	>=220,0	243,9	1
A50	%	>=40,0	52,4	1
EXPANSION	%	>=30,0	OK	1
C TOT. RES. IN.	mg/dm <sup>2</sup>	<=0,38	0,08	1
ECT EN 1971	%	100	OK	-

### DECLARATION OF COMFORMITY

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance system applied to monitor their production, complies to the requirements of ISO 9001/2008, independently certified by TÜV HELLAS, with registration No 041070119.

Athens

25.08.2017

Q.C. INSPECTOR

Q.A. MANAGER



D. SKARMOUTSOS

FORM N3

ISSUE C

REV 1

DATE JUL-2014

e-mail: info@halcor.com  
website: www.halcor.com  
VAT number: EL094061318

Offices & Copper Tube Plant (Mailing Address)  
62<sup>nd</sup> km Athens-Lamia National Road,  
GR-32011 Inofita-Viotia, GREECE  
Tel.: +30 22620 48111, Fax: +30 22620 48911

Foundry  
60<sup>th</sup> km Athens-Lamia National Road,  
GR-32011 Inofita-Viotia, GREECE  
Tel.: +30 22620 53479, Fax: +30 22620 53925

Domestic Sales Dept  
252 Pireos str.  
GR-17778, Tavros, Athens, GREECE  
Tel.: +30 210 4898111, Fax: +30 210 4898397