

Athens the	03.08.2017
Inspection Lot	020000435767
Sales Order No	15008204 / 230
Delivery Document	0085150720
Certificate No	1000321556
Customer's Ref No	LOADING 02/08

Declaration of Conformity according to EN 1655

DECLARATION OF CONFORMITY

The products, listed here-below in the shown quantities, are made from *Cu-DHP* and conform to the specifications *EN 1057 R290*. as well as to the conditions and requirements of the purchaser *COPPER COM D.O.O.*.

Designation COPPER TUBES 028,000x1,00x5000, STRAIGHT, FOR SANITARY USE,	
Quantity	544,00 KG

The quality assurance system applied to monitor the production of the above products, is in compliance to the requirements of ISO 9001/2008 and independently certified by TUV HELLAS, with registration No 041070119.

The Q.A. Manager

D. SKARMOUTSOS

GR-17778, Tavros, Athens, GREECE Tel.: +30 210 4898111, Fax: +30 210 4898397

252 Pireos str.



HALCOR S.A., 57th km National Road Athens-Lamia, GR 32011 Inofyta Viotias

08 001 CPR 06.2013

EN 1057

Seamless, round copper tubes for water and gas in sanitary and heating applications

Intended to be used in :

- Drainage, and disposal of other liquids and gaseous waste;
- Supply of fuels, oil and other liquids (including hot water heating systems);
- Fire suppression and extinguishing systems;
- Supply of gases, pressure and vacuum systems;
- Storage fixtures.

Product designation:

COPPER TUBES 028,000x1,00x5000, STRAIGHT, FOR SANITARY USE,

Reaction to fire: Crushing strength: Internal pressure: Dimensional tolerances:

Resistance to high temperature:

Weldability:

Tightness: gas and liquid:

Durability of crushing strength,

Class A.1

NPD NPD pass

Suitable for use to 120 °C

pass pass