

Athens the	25.07.2017
Inspection Lot	020000435392
Sales Order No	15008185 / 300
Delivery Document	0085150251
Certificate No	1000320677
Customer's Ref No	LOADING 25/7

Declaration of Conformity  
according to EN 1655

## DECLARATION OF CONFORMITY

The products, listed here-below in the shown quantities, are made from *Cu-DHP* and conform to the specifications *EN 1057,R290*. as well as to the conditions and requirements of the purchaser *COPPER COM D.O.O.*.

Designation	<b>COPPER TUBES 042,000x1,50x5000, STRAIGHT, FOR SANITARY USE,</b>
Quantity	<b>559,00 KG</b>

The quality assurance system applied to monitor the production of the above products, is in compliance to the requirements of ISO 9001/2008 and independently certified by TUV HELLAS, with registration No 041070119.

The Q.A. Manager



D. SKARMOUTSOS



HALCOR S.A., 57th km National Road Athens-Lamia,  
GR 32011 Inofyta Viotias

08  
001 CPR 06.2013

**EN 1057**

Seamless, round copper tubes for water and gas in sanitary and heating applications

Intended to be used in :

- Drainage, and disposal of other liquids and gaseous waste;
- Supply of fuels, oil and other liquids (including hot water heating systems);
- Fire suppression and extinguishing systems;
- Supply of gases, pressure and vacuum systems;
- Storage fixtures.

Product designation:

**COPPER TUBES 042,000x1,50x5000, STRAIGHT, FOR SANITARY USE,**

Reaction to fire:	Class A.1
Crushing strength:	NPD
Internal pressure:	NPD
Dimensional tolerances:	pass
Resistance to high temperature:	Suitable for use to 120 °C
Weldability:	pass
Tightness: gas and liquid:	pass
Durability of crushing strength,	