



PLA-SM SERIES

SERIES SELECTION

Indoor Unit



PLA-SM71/100/125/140EA

Outdoor Unit



SUZ-SM71VA



PUZ-SM100/125/140VKA2
PUZ-SM100/125/140YKA2

Optional

PLP-6EAJ - Panel only

PLP-6EALM - Panel with signal receiver and wireless remote controller



PAR-41MAA(B)
DELUXE



PAC-YT52CRA



PAR-SL100A*

*Enclosed with PLP-6EALM

PLA-SM SERIES

Type				Inverter Heat Pump							
Indoor Unit				PLA-SM71EA	PLA-SM100EA			PLA-SM125EA		PLA-SM140EA	
Outdoor Unit				SUZ-SM71VA	PUZ-SM100VKA	PUZ-SM100YKA	PUZ-SM125VKA	PUZ-SM125YKA	PUZ-SM140VKA	PUZ-SM140YKA	
Refrigerant				R32 ^(*)							
Power Supply				Outdoor power supply							
Source				VA - VKA:230 / Single / 50, YKA:400 / Three / 50							
Outdoor (V / Phase / Hz)											
Cooling	Capacity	Rated	kW	7,1	9,5	9,5	12,1		13,4		
		Min-Max	kW	2,2-8,1	4,0-10,6	4,0-10,6	5,8-13,0		5,8-14,1		
	Total Input	Rated	kW	1,97	2,79	2,79	4,17		5,13		
	EER			3,6	3,4	3,4	2,9		2,61		
	EEL Rank			-	-	-	-		-		
	Design load		kW	7,1	9,5	9,5	12,1		13,4		
	Annual electricity consumption ^{(*)2}		kWh/a	410	554	554	-		-		
	SEER			6	6	6	-		-		
Energy efficiency class				A+	A+	A+	-		-		
Heating (Average Season)	Capacity	Rated	kW	8	11,2	11,2	13,5		15		
		Min-Max	kW	2,0-10,2	2,8-12,5	2,8-12,5	4,1-15,0		4,2-15,8		
	Total Input	Rated	kW	2,28	3,1	3,1	3,73		4,54		
	COP			3,5	3,61	3,61	3,61		3,3		
	EEL Rank			-	-	-	-		-		
	Design load		kW	5,8	8	8	8,5		9,4		
	Declared Capacity	at reference design temperature	kW	5,2 (-10°C)	6,0 (-10°C)	6,0 (-10°C)	8,5 (-10°C)		9,4 (-10°C)		
		at bivalent temperature	kW	5,2 (-7°C)	7,0 (-7°C)	7,0 (-7°C)	8,5 (-10°C)		9,4 (-10°C)		
		at operation limit temperature	kW	5,2 (-10°C)	4,5 (-15°C)	4,5 (-15°C)	6,0 (-15°C)		7,0 (-15°C)		
	Back up heating capacity		kW	0,6	2	2	0		0		
Operating Current (Max)	Input (cooling/heating)	Rated	kW	15,1	20,5	12	27,2	12,2	30,7	12,2	
	Operating Current (Max)		A	0,04	0,07	0,07	0,1	0,1	0,1	0,1	
	Dimensions <Panel>	HxWxD	mm	258x840x840<40x950x950>			298x840x840<40x950x950>				
	Weight <Panel>		kg	21<5>	24<5>		26<5>				
	Air Volume (Lo-Mid-Hi)		m³/min	14-17-19-21	19-23-26-29		21-25-28-31		24-26-29-32		
	Sound Level (Lo-Mid-Hi) (SPL)		dB(A)	28-30-32-34	31-34-37-40		33-37-41-44		36-39-42-44		
	Sound Level (PWL)		dB(A)	56	61		65		65		
	Dimensions	HxWxD	mm	880x840x330			981x1050x330 (+40)				
Indoor Unit	Weight		kg	55	76	78	84	85	84	85	
	Air Volume	Cooling	m³/min	50,1	79	79	86	86	86	86	
		Heating	m³/min	50,1	79	79	92	92	92	92	
	Sound Level (SPL)	Cooling	dB(A)	49	51	51	54	54	55	55	
		Heating	dB(A)	51	54	54	56	56	57	57	
	Sound Level (PWL)	Cooling	dB(A)	66	70	70	72	72	73	73	
	Operating Current (Max)		A	14,8	20	11,5	26,5	11,5	30	11,5	
	Breaker Size		A	20	32	16	32	16	40	16	
Outdoor Unit	Diameter	Liquid/Gas	mm	9,52 / 15,88							
	Max. Length	Out-In	m	30							
	Max. Height	Out-In	m	30							
Ext. Piping	Guaranteed Operating Range	Cooling	°C	-15 ~ +46							
		Heating	°C	-10 ~ +21							
Refrigerant/GWP				R32/675 ^{(*)4}							
Pre-Charged quantity	Weight		kg	1,45	3,1	3,1	3,6	3,6	3,6	3,6	
	CO ₂ equivalent		t	0,98	2,09	2,09	2,43	2,43	2,43	2,43	
Max added quantity	Weight		kg	2,37	4,1	4,1	5	5	5	5	
	CO ₂ equivalent		t	1,6	2,77	2,77	3,38	3,38	3,38	3,38	

^{(*)1} Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 1975. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 1975 times higher than 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

^{(*)2} Energy consumption based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.

^{(*)3} Optional air protection guide is required where ambient temperature is lower than -5°C.

^{(*)4} This GWP value is based on Regulation(EU) No 517/2014 from IPCC 4th edition.